



999 WEST VALLEY ROAD • WAYNE, PENNSYLVANIA 19087 • (215) 971-0900

CONFIDENTIAL

PFF
ORIGINAL
(Red)

C-51-6-2-78

June 12, 1992

Project Number 3738-43

Mr. Gregory Ham
U.S. Environmental Protection Agency
841 Chestnut Building
Ninth and Chestnut Streets
Philadelphia, Pennsylvania 19107



Reference: ARCS III Program
EPA Contract No. 68-W8-0037

Subject: Final Report
Work Assignment No. 37-38-3JZZ
Site Inspection Prioritization
EPA ID No. PAD000862821
EPA DSN PA-0193
Chalfont Borough Water Distribution
Chalfont, Bucks County, Pennsylvania

Dear Mr. Ham:

Attached, please find the final Site Inspection Prioritization (SIP) report for the subject site. HALLIBURTON NUS Environmental Corporation was tasked to conduct a Level 1 SIP assessment of the site. The site is a water supply well (well 8-A) that exhibited low levels of tetrachloroethylene (≤ 14 ug/l) and trichloroethylene (≤ 1.0 ug/l) contamination in 1979. In 1989 and again in 1992, the well was sampled and analyzed by the Chalfont Borough Water Department for volatile organic compounds (VOCs). No VOC contamination was detected during these monitoring events. A source of contamination has not been identified and, based on the recent monitoring results, investigation of potential sources has not been implemented. Based on this information, it is recommended that EPA consider the following:

- No further action should be taken for the subject site. A Hazard Ranking System (HRS) PRescore has not been calculated; however, a score of zero would be assigned due to the lack of a source of contamination at the identified location. In addition, the well is monitored by the water department in accordance with the Pennsylvania Safe Drinking Water Act requirements.

If you have any questions, please feel free to contact either [redacted] the HALLIBURTON NUS site manager, or [redacted] the HALLIBURTON NUS project manager.

Respectfully submitted,

[redacted]
non responsive based on revised scope

Site Manager

Reviewed by [redacted]
non responsive based on revised scope

Project Manager

Approved by [redacted]
non responsive based on revised scope

Program Manager, ARCS III

[redacted] law